## Garden State Laboratories, Inc.

THE STATE OF THE PARTY OF THE P

Bacteriological and Chemical Testing

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 Email: info@gslabs.com Internet: www.gslabs.com

Main Lab 410 Hillside Avenue Hillside, New Jersey 07205 NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Jordan B. Klein, B.A., Exec. Vice President Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

Jersey Shore Lab 54 Main Street Waretown, New Jersey 08758 NJDEP Lab Cert. #15037

REPORT # 390206084.0

CLIENT # NEW02

DATE SUBMITTED: 2/6/2019

TO: New Jersey Institute of Technology University Heights

Newark NJ 07102

ATT: Mitchell Gayer

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: NEW NJIT PO # UB100558, MUNICIPAL WATER POTABILITY

SAMPLE LOCATION: #002-LSEC-2ND FL LAB ROOM 202, NJIT CAMPUS-LIFE

SCIENCE & ENGINEERING CENTER

DATE SAMPLED: 2/6/2019 TIME SAMPLED: 08:58

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Total Coliform, Col.18, SM9223B	Absent	organisms/100 ml	Absent	2/6/19-17:08
Heterotrophic Plate Ct., SM9215B	<5	cfu/ml	Rec. 500	2/6/19-17:08
Total Hardness, SM 2340 C	34.7	mg/l as CaCO3	250	2/8/19
Lead, EPA 200.9	<0.001	mg/l	0.015	2/8/19
Copper, SM 3111B	0.155	mg/l	1.3	2/8/19
pH, SM 4500 H+B	6.31*	Standard Units	6.5-8.5	2/6/19-19:37
T. Dissolved Solids, SM 2540C	128	mg/l	500	2/11/19
Iron, Total, EPA 200.7	0.260	mg/l	0.3	2/8/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

\*Submitted past holding time.

392639